



ADDENDUM TO IFB DOCUMENTS
April 26, 2013

IFB No. 26-12-13 City Hall Roof Removal & Replacement

BID OPENING DATE: May 7, 2013 @ 3:00 PM

ADDENDUM No. 4

To All Bidders:

It is the Bidders' responsibility to assure receipt of all addenda. The Bidder should verify with the designated Purchasing Agent prior to submitting a bid that all addenda have been received. Bidders are required to acknowledge the number of addenda received as part of their bid by checking the box indicated on the bid form.

This addendum is issued to modify the previously issued IFB documents and/or given for informational purposes, and is hereby made a part of the bid documents.

The following questions were submitted and become part of this IFB.

In review of Addendum #3 – Core Test Results

- 1. The core results for the 2nd floor balcony roof system, indicates the following:**
 - Modified hot mopped**
 - 2 ply glass hot mopped**
 - 1/2" perlite recovery board**
 - Ceramic tile**

Do we know the condition under the ceramic tile, is there light structural concrete under the ceramic tile? Is the tile direct to concrete slab? We need to know what is under the ceramic tile, there are no roofing manufacturer NOA's for permitting, that allows a new roof system to be attached to ceramic tile. Please advise.

- A. See Attachment A – Original City Hall Blueprint**

*****All other items remain the same*****