



**ADDENDUM TO
SOLICITATION DOCUMENTS**

Posted Date: July 7, 2014

Addendum No. 02

Solicitation Title: Police Department (2) Chiller and Controls Replacement

Solicitation No.: 42-13-14 IFB Opening Date: Tuesday, July 15, 2014 at 3:00PM

To All Respondents:

It is the Respondents' responsibility to assure receipt of all addenda, clarifications and inquiries regarding this Solicitation. The Respondent should verify with the designated Purchasing Agent prior to submitting a response, that all, if any, have been received. Respondents are required to acknowledge the number of addenda received as part of their response by checking the box indicated on the City Contract Form, A-5 Acknowledgement of Addendum(s).

This addendum is issued to modify the previously issued Solicitation documents and/or given for informational purposes, and is hereby made a part of the Solicitation documents.

NOTIFICATION OF BID ACTIVATION

By way of this Addendum, the above referenced solicitation has been re-activated. This Solicitation will open on Tuesday, July 15th, 2014 at 3:00PM.

Q1: Will the Contractor be required to re-insulate the chillers to the building?

A1: Re-insulate all existing and new piping with 2½ inch thick outdoor insulation with protective metal jacket. From new chillers to building piping penetration, includes all valves, pumps and air tank. Replace all existing chilled water valves. If the building must be shut down for any reason it must be done on a Saturday for the two main valves.

*****All other items remain the same*****
End of Addendum