



**ADDENDUM TO IFQ DOCUMENTS**  
**February 22, 2013**

**IFQ No. 20-12-13 Enchanted Forest Stable Roof Replacement**

**BID OPENING DATE: February 27, 2012 @ 3:00 PM      **ADDENDUM No. 1****

To All Bidders:

It is the Bidder's responsibility to assure receipt of all addenda. The Bidder should verify with the designated Purchasing Agent prior to submitting a bid that all addenda have been received. Bidders are required to acknowledge the number of addenda received as part of their bid by checking the box indicated on the bid form.

This addendum is issued to modify the previously issued IFQ documents and/or given for informational purposes, and is hereby made a part of the bid documents.

---

---

**The following question(s) were submitted and becomes a part of the bid document:**

1. Can we request a copy of the sign in sheet?

**A. See attached**

2. #6 – Are we are to tear off existing roof and replace the damaged T-111 wood as needed?

**A. Yes**

3. #7 – Are we to install new 5/8" plywood on top of the existing wood decking on all roof areas or just the T-111 areas? Or are we to remove all existing plywood decking and replace with new? Are we suppose to tear off existing roofing and replace only the damaged plywood and T-111 decking as needed, as stated in #4

**A. The new 5/8" plywood will be replaced only in the areas were needed on other parts of the roof and all over the T-111 deck. There is currently no plywood over the T-111 deck. So that will need to be installed.**

4. What is the type of plywood and T1-11 siding to be used, pressure treated or non-pressure treated?

**A. Non-Pressure Treated. Please note that the T-111 will be painted.**

**NOTE: Paint Color for T-111: P-3 Light green semi-gloss / Stein Paint**

5. Are the (3) pgs on the website the only information for this bid? Also, is there an estimated or set budget?

**A. Yes the three pages are the complete specs / Budget is set for \$35,000**

6. Will bonding be required for this project?. If so, will be need to submit a bid bond?  
**A. No bonding is not required**

\*\*\*\*\*All other items remain the same\*\*\*\*\*

# Enchanted Forrest Roof Replacement

## Pre-bid Walkthrough

February 15, 2013 at 9:00am

Name	Company	Address	Telephone	E-mail
Travis Kreiner	AI Roof Roofing	8095 NW 64th St, Miami FL	(305) 955-5525	tdkreiner@aia-roofing.com
AL HESS	UNLIMITED Pfy	7845 NW 46th St Miami	305-965-3236	AL@UNLIMITEDroofing.com
DRUD JOHNSA	SUPREME ROOFING	2600 NW 156th	786 2299331	RFP@forSmith@atrap.com
MARK DOZIER	DOZIER & DOZIER	1065 N.E. 125th St #101	786.229.1549	m.dozier@dozieranddozier.com
KRISTIAN IZK	Preventive Maint.	1110 2nd Ave S L.W	561 5865655	kris@preventiveSupport.com
CHRIS BARDEA	Cencon Concrete Cutting	270 NW 19th Blvd	305-769-3979	cb@8844671@aol.com
JOE A. UZCATEGUI	BETA CALUM, LLC	12550 BISCAYNE BLVD.	786-442-3142	auzcategui@betacalum.com
Carlson Daniel	Kamel's Place LLC	8940 NW 9th St #100 Miami FL 33150	305-206-1566	KamelsPlace@gmail.com
DAVID COPPIN	Atlas Roofing	8515 Deerfield Ave. Deerfield	954-270-0615	david@atlasroofingfl.com
WILSON & HENRY	WPH Construction	10822 NW 7th Ave	305 2442392	WPHConstruction@gmail.com
GEORGE ORDOZIO	TEQUESTA COAT	1101 SW 64th St	305 7934391	wwtequestaconstruction.com
ALBERTO KNOVELLA	Dozier/Dozie	1065 NE 125th St.	305 970-7619	
LARRY BELTON	Blueprint Industrial	1747 WASHING St.	305-333-8110	Larrybelton@hotmail.com
R. RICHARD RAYMOND	MFR CONSTRUCTION	300 NW 144th St. Miami FL 33168	(786) 547-1583	mfrconstructioninc.com