



**ADDENDUM TO BID DOCUMENTS  
July 12, 2010**

**IFB No. 49-09-10      Sanitary Sewer Force Main Replacement**

**IFB OPENING DATE: August 10, 2010@ 3:00 PM      **ADDENDUM No. 2****

To All Bidders:

It is the Bidders responsibility to assure receipt of all addenda. The Bidder should verify with the designated Contracting Officer prior to submitting a proposal that all addenda have been received. Bidders are required to acknowledge the number of addenda received as part of their proposals utilizing Form A-5 "Acknowledgement of Addenda".

This addendum is issued to modify the previously issued IFB documents and/or given for informational purposes, and is hereby made a part of the IFB documents.

- 
- 1.      Would the City entertain Directional Boring with either Fusible C-905 PVC or DIP'S HDPE Pipe as an alternate to open cut construction?**
    - A.      Yes providing they meet all the designer specs**
  - 2.      Please clarify what is the contract time duration and by when is the proposed force main supposed to be in service**
    - A.      The project is to be completed within 180 days from the Notice to Proceed.**
  - 3.      Clarify if a field office is going to be required by the contractor and at the contractor's expense**
    - A.      A field office is not required**
  - 4.      Clarify if lab fees and density testing is required and at contractor's expense**
    - A.      Yes and yes. Please refer to the general notes and specifications on sheet C1 of the contract drawings. Please see Item III. Inspection and Testing and Item IX. Paving. Also, please refer to contract specifications Section 01410 Testing and Testing Lab Services.**

Everything else remains the same

---